

VARIOUS CONTROL TECHNIQUES FOR POWER QUALITY IMPROVEMENT USING DSTATCOM

R.GEETHA

M.E-power electronics and drives
Dr.Paul's engineering college
Villupuram,
trsgeetha@rediffmail.com

M.AISHWARIYA DEVI

M.E-power electronics and drives
Dr.Paul's engineering college
Villupuram,
Devi.aishwariya@yahoo.com

Abstract— This paper focuses on the control techniques employed for Distribution Static Compensator. Distributed static compensator is a device used for power quality improvement. Here we considered voltage source converter based distributed static compensator. It describes to control distribution Static Compensator employed at the distribution end. The phase shift control and AC bus /DC link voltage schemes have been incorporated to control DSTATCOM employed at the distribution end. It describes the salient features of each strategy, with their merits and demerits.

Keywords-DSTATCOM, harmonic mitigation, phase shift control, AC bus/DC link voltage regulation, power quality, reactive power compensation

I. INTRODUCTION

In a power distribution networks, reactive power is the main cause of increasing distribution system losses and various power quality problems. Conventionally, static var compensators (SVC) have been used in conjunction with passive filters at the distribution level for reactive power compensation and mitigation of power quality problems [1]. Though SVCs are very effective system controllers used to provide reactive power compensation at the transmission level, their limited bandwidth, higher passive element count that increases size and losses, and slower response make them inapt for the modern day distribution requirement. Another compensating system has been proposed by [2], employing a combination of SVC and active power filter, which can compensate three phase loads in a minimum of two cycles. Thus, a controller which continuously monitors the load voltages and currents to determine the right amount of compensation required by the system and the less response time should be a viable alternative. Distribution static compensator(DSTATCOM) has the capacity to overcome the above mentioned drawbacks by providing precise control and fast response during

transient and steady state. A DSTATCOM is basically a converter based distribution flexible AC transmission controller sharing many similar concepts with that of a static compensator(STATCOM) used at the transmission level. At the transmission level, STATCOM handles only fundamental reactive power and provides voltage support, while a DSTATCOM is employed at the distribution level or at the load end for dynamic compensation. The latter, DSTATCOM, can be one of the viable alternatives to SVC in a distribution network. Additionally, a DSTATCOM can also behave as a shunt active filter [3,4], to eliminate unbalance or distortion in the source current or the supply voltage, as per the IEEE-519 standard limits. Since a DSTATCOM is such a multifunctional device, the main objective of any control algorithm should be to make it flexible and easy to implement, in addition to exploiting its multi functionality to the maximum. Prior to the type of control algorithm incorporated, the choice of converter configuration is an important criterion. The two converter configurations are voltage source converter or current source converter, in addition to passive storage element either a capacitor or an inductor respectively. Normally, voltage source converter are preferred due to their smaller size, less heat dissipation and less cost of the capacitor, as compared to an inductor for the same rating [5-6]. This paper focuses on the comparative study of the control techniques for voltage source converter based DSTATCOM, broadly classified into voltage control DSTATCOM and current control DSTATCOM.

II. BASIC PRINCIPLE OF DSTATCOM

A DSTATCOM is a controlled reactive source, which includes a voltage source converter (VSC) and a DC link capacitor connected in shunt, capable of generating and/ or absorbing reactive power. The operating principles of DSTATCOM are based on the exact equivalence of the conventional rotating synchronous compensator. The AC terminals of the VSC are not connected to the point of common coupling(PCC) through an inductance, which could be a filter inductance or leakage inductance of the coupling transformer, as shown in figure 1.




Figure1: Basic Structure of Dstatcom

The DC side of the converter is connected to a DC capacitor, which carries the input ripple current of the converter and is the main reactive storage element. This capacitor could be charged by a battery source, or could be precharged by the converter itself. If the output voltage of the VSC is equal to the AC terminal voltage, no reactive power is delivered to the system. If the output voltage is greater than the AC terminal voltage, the DSTATCOM is in the capacitive mode of operation and vice versa. The quantity of the reactive power flow is proportional to the difference in the two voltages. The voltage regulation at PCC and power factor correction cannot be achieved simultaneously. For a DSTATCOM used for voltage regulation at the PCC, the compensation should be such that the supply current should lead the supply voltages; whereas, for power factor correction, the supply current should be in phase with the supply voltages. The phase shift control are used to study the performance of a DSTATCOM for power factor correction and harmonic mitigation.

III. CONTROL STRATEGIES

The control strategies of a DSTATCOM are mainly implemented in the following steps:

- Measurement of system variables and signal conditioning.
- Extraction of reference compensating signals.
- Generation of firing angles for switching devices

Figure2. shows the schematic diagram of DSTATCOM control. The generation of proper pulse width modulation (PWM) firing is the most important part of DSTATCOM control and it has a great impact on its compensation objectives, transients as well as steady state performance. Since a DSTATCOM shares many concepts with that of STATCOM at the transmission level, a few control techniques have been directly implemented to a DSTATCOM, incorporating PWM switching, rather than fundamental frequency switching(FFS) methods. A PWM based distribution static compensator offers faster response and capability for harmonic elimination. There are three methods of DSTATCOM

for power factor correction and harmonic mitigation based on:

1. Phase shift control
2. Indirect decoupled current control
3. Regulation of AC bus and DC link voltage




Figure2: Schematic diagram of DSTATCOM control

IV. PHASE SHIFT CONTROL

The schematic diagram of phase shift control is shown in figure3. In this method, the compensation is achieved by the measuring of the rms voltage at the load point, whereas no reactive power measurements are required [7,8]. Sinusoidal pulse width modulation technique is used with constant switching frequency. The error signal obtained by comparing the measured system rms voltage and the reference voltage is fed to the proportional integral(PI) controller, which generates the angle for deciding the necessary phase shift between the output voltage of the VSC and the AC terminal voltage. This angle is summed with the phase angle of the balanced supply voltages, assumed to be equally spaced at 120 degrees, to produce the desired synchronizing signal required to operate the PWM generator. In this scheme, the DC voltage is maintained constant, using a separate battery source. It is observed that the source current and the source voltage are in phase, correcting the power factor of the system in case of a linearly varying load; whereas, complete compensation is not achieved in case of nonlinear load (source current THD 24.34%) though this strategy is easy to implement, is robust and can provide partial reactive power compensation without harmonic suppression, it has the following disadvantages

1. The controller does not use a self supporting DC bus and thus requires a very large DC source to pre charge the capacitor.
2. Balanced source supply as rms voltages assumed and the supply phase angle are calculated over the fundamental only.

- No harmonic suppression and partial compensation is achieved in case of nonlinear loads




Figure3: Block Diagram of Phase Shift Control




Figure 4: Block diagram using regulation of AC/DC link voltage scheme

V. REGULATION OF AC BUS AND DC LINK VOLTAGE

Three phase AC supply voltages and DC link voltage are sensed and fed to two PI controllers, the outputs of which decide the amplitude of reactive and active current to be generated by the DSTATCOM[9]. Figure3 shows the block diagram of AC/DC link voltage scheme. Multiplication of these amplitudes with the in phase and quadrature voltage unit vectors yields the respective component of the reference currents. When applying the algorithm for power factor correction and harmonic elimination, the quadrature component of the reference current is made zero. These reference currents and the sensed line currents are fed to a hysteresis controller, which is used for tracking control. This hysteresis controller, adds a hysteresis band $\pm h$ around the calculated reference current.

The switching is obtained as given below:

If $i_{sa} > (i_{sa_ref} + h)$, the upper switch of inverter leg corresponding to phase 'a' is ON and the lower switch is OFF.

If $i_{sa} < i_{sa_ref} - h$, the upper switch of inverter leg corresponding to phase 'a' is OFF and the lower switch is ON.

PARAMETERS	EFFECT ON PHASE SHIFT CONTROL
Reactive power compensation	Partial
Performance under balanced and nonlinear loads	Contains undesired harmonics in case of nonlinear load
Applicable for single phase systems	Yes
Harmonic compensation capability	Well above 5% (no harmonic compensation)
PWM switching frequency	Fixed
Self supporting DC bus	No
Generation of firing pulses	Sine PWM

The tracking becomes better if the hysteresis band is narrower, but the switching frequency is increased, which results in increased switching losses. Therefore, the choice of hysteresis band should be a compromise between tracking error and inverter losses[10]. This method of tracking current control is simple and robust and it exhibits an automatic current limiting characteristic. This compensation scheme is multi-functional and can also be effectively used for load unbalancing and harmonic suppression, in addition to power factor correction and dynamic voltage regulation. The transient period is very short and complete reactive power compensation and power factor correction is achieved in case of both linear/nonlinear load, the THD of the source current is 2.01%, well below the IEEE-519 standard for harmonic suppression.

The advantages of this scheme are:

- The derivation of switching signals uses a hysteresis controller, which is robust and simple, with fast dynamic response and automatic current limiting capability.
- The algorithm is flexible and can easily modified for improved voltage regulation, harmonic suppression and load balancing.
- The inherent property to provide self-supporting DC bus does not requires complex abc_qd0 transformations.
- The THD in case of nonlinear load is well below the IEEE 519 standard limits.

VI. COMPARISON OF PHASE SHIFT CONTROL AND AC bus/DC LINK VOLTAGE

PARAMETERS	EFFECT ON AC/DC LINK VOLTAGE
Reactive power compensation	Complete
Performance under balanced and nonlinear loads	Satisfactory in case of linear loads
Applicable for single phase systems	No
Harmonic compensation capability	13.21% (above 5% limit)
PWM switching frequency	Fixed
Self supporting DC bus	Yes
Generation of firing pulses	Sine PWM

VII. CONCLUSION

This paper present the comparative study between phase shift control and AC bus/DC link voltage, which is used for the control of DSTATCOM. The control scheme are described under linear and non-linear loads. It can be concluded that though conceptually similar to a STATCOM at the transmission level, a DSTATCOM's control scheme should be such that in addition to complete reactive power compensation, power factor correction and voltage regulation of the harmonics are also checked, in order to achieve improved power quality levels at the distribution end.

REFERENCES

- 1.J.Dixon, L.Moran, and Rodriguez, Reactive power compensation technologies: state of art Review, proceedings of the IEEE.vol.93.No.12,2005.
- 2.J.Dixon, Y.del valle, M. Orchard, M.Ortizar, L.Moran, and C.Maffrand, A full compensating system for general loads based on the combination of thyristor binary compensator, and a PWM-IGBT active power filter,IEEE trans. On industrial electronics.vol.18, No.4, oct.2003, pp. 982-9.
- 3.J.Nastran, R.Cajhen,M.Seliger,and P.Jereb, active power filters for nonlinear AC loads, IEEE trans. On power electronics.vol.9.no.1,pp.92-6,jan. 1994.
- 4.L.A.Moran,J.W.Dixon, and R.R.Wallace, A three phase active power filter with fixed switching frequency for reactive power and current harmonic compensation, IEEE Trans. On Industrial Electronics.vol.42,pp.402-8,Aug.1995.
- 5.L.TMoran,P.D.Ziogas, and G.Joos, analysis and design of a three phase current source solid state var compensator, IEEE trans, on Industry applications.Vol.25.No.2,1989,pp.356-65.

6.M.Mishra,A.Ghosh, and A.Joshi, operation of a DSTATCOM in volume control mode, IEEE trans, On power delivery,vol.18,No.1,pp.266-272,Jan.2002.

7.O.A.Lara, and E.Acha,Modelling and analysis of custom power systems by PSCAD/EMTDC,IEEE Trans, on power delivery.vol.17.No.1,pp.266-272,Jan.2002.

8.C.Schauder, and H.Mchta, Vector analysis and control of advanced Static VAR Compensators.TEE proceedings-c.vol.140,pp.299-306,July.1993

9.. JB.N.Singh,Bhim Singh,A.Chandra, and Kamal Al Haddad, digital implementation of an advanced static compensator for voltage profile improvement, power factor correction and balancing of unbalanced reactive loads, electric power systems research 54(20001101-11).

10. A.Ghosh, and G.Ledwich, power quality enhancement using custom power devices, Kluwer, academic publishers, London 2002.